



21	AR	U-BOLT PG CLAMPS	402371	S01-1-4-25
20	AR	OVERHEAD CONDUCTOR	-	-
19	6	TOUNGE HOOK	292680	.....
18	6	THIMBLE CLEVIS	6767	S01-1-4-03
17	2	M24 BOLT AND NUT, 65MM LONG	400800	S01-1-4-43
16	1	M24 INSULATOR STUD 75MM LONG	298745	S01-1-4-44
15	2	M16 SPRING WASHER	114322	S01-1-4-43
14	4	M24 SPRING WASHER	114330	S01-1-4-43
13	4	M16 FLAT WASHER	114348	S01-1-4-43
12	8	M24 FLAT WASHER	298828	S01-1-4-43
11	2	M24 BOLT AND NUT 180MM LONG	400802	S01-1-4-43
10	2	M24 INSULATOR STUD 175MM LONG	300483	S01-1-4-44
9	2	ANGLE CROSS ARM BRACE	400815	S01-1-4-38
8	2	M16 BOLT AND NUT 160MM LONG	114579	S01-1-4-43
7	1	M24 BOLT 50MM LONG	114629	S01-1-4-43
6	2	M24 BOLT 220MM LONG	400803	S01-1-4-43
5	2	18KN EYE NUT	298711	S01-1-4-41
4	1	FIBRE GLASS HV TERMINATION CROSS ARM	406938	S01-1-2-10
3	2	SHACKLE STRAP	406938	S01-1-4-37
2	3	22KV POST TOP INSULATOR	300467	S01-1-3-10
1	6	22KV 70KN STRAIN INSULATOR	292656	S01-1-3-09
ITEM	QTY	DESCRIPTION	STOCK CODE	DRG No.

**MATERIAL SCHEDULE**

NOTES:

- DOUBLE PG CLAMPS PER CONNECTION SHALL BE USED ON FEEDER BACKBONES.

2	TERMINATION CROSS ARM UPDATED	C.C.	NOV'11	A.T.	S.C.
1	REDRAWN IN 3D	J.C.	OCT'09	A.T.	S.C.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	A.T.	POWER STANDARD DRAWING		
DRN	J.C.	<b>ASSEMBLIES. INSULATORS ON H/V. C TOP FOR UNIVERSAL POLE CONSTRUCTION.</b>		
CKD	A.T.			
APPD	S.C.			
SCALE	N.T.S.			
ISSUED	OCT'09	<b>A3</b>	<b>DRAWING NUMBER</b>	<b>S01-2-1-52</b>
ALL DIM. IN	mm			
DRAFTING STANDARD TO A.S.1100			CAD PRODUCT - DO NOT AMEND MANUALLY	

