



NOTES

1. CONDUIT TO BE RUN BETWEEN CONTROL BOX AND POLE
2. A MAINS CONNECTION BOX TO SUIT THE NUMBER OF CABLES AND 32MM CONDUIT SHALL BE INSTALLED AT THE POLE TOP END OF THE CONDUIT.
3. 16S0MM COPPER SDI CABLE SHALL BE RUN FROM THE CONTROL BOX TO THE STREETLIGHT CIRCUIT AND LV MAINS

**ISOMETRIC VIEW
CONTROL BOX MOUNTING**
N.T.S.

NO	DESCRIPTION	DRN	DATE	CKD	APPD
0	ISSUED FOR CONSTRUCTION	J.C.	JUL '11	A.T.	S.C.
AMENDMENTS					



DES	A.T.	POWER STANDARD DRAWING		
DRN	J.C.	CONTROL BOX MOUNTING DETAILS		
CKD	M.B.			
APPD	S.C.			
SCALE	N.T.S.			
ISSUED	JUL '11	A3	DRAWING NUMBER	S03-1-5-17
ALL DIM.	IN mm			
DRAFTING STANDARD TO A.S.1100			CAD PRODUCT - DO NOT AMEND MANUALLY	

