

METER SOCKET - 3 JAW
(EMAIL CAT. No. 828140)

A	ISSUED FOR COMMENT	A.S.	18.1.02	
NO	DESCRIPTION	DRN	DATE	APPD
AMENDMENTS				



DES	
DRN	A.SCHMID
CKD	
APPD	
SCALE	1:2
ISSUED	
ALL DIM. IN mm	
DRAFTING STANDARD TO A.S.1100	

FIG.22 - COMPONENT DRILLING DETAILS METER SOCKET	
A4	DRAWING NUMBER S11-2-7-23
CAD PRODUCT - DO NOT AMEND MANUALLY	
AMDT	

NOTE :

PANEL AREA REQUIRED

MIN. WIDTH 175mm

MIN. HEIGHT 280mm

TYPICAL
SINGLE PHASE METER

20



11

22

22

22

DRILL 4 HOLES $\phi 12$ IN METER
PANEL FOR CABLE ACCESS

	0	APPROVED FOR INSTALLATION	R.W.	4.9.09	N.C.	DES N.COAD	FIG.22b SINGLE PHASE kWh METER DRILLING DETAILS FOR CABLE ACCESS SHEET 2
	A	ISSUED FOR COMMENT	R.W.	4.9.09	N.C.	DRN R.WILLIAMS	
	NO	DESCRIPTION	DRN	DATE	APPD	CKD N.COAD	
	AMENDMENTS					APPD B.KISON	
						ALL DIM. IN mm	A4 DRAWING NUMBER S11-2-7-23
						DRAFTING STANDARD TO A.S.1100	CAD PRODUCT — DO NOT AMEND MANUALLY 

NOTE :

PANEL AREA REQUIRED

MIN. WIDTH 180mm

MIN. HEIGHT 330mm


TYPICAL
POLYPHASE
WHOLE CURRENT METER

20

7

18 18 18 18 18 18 18

DRILL 8 HOLES $\phi 12$ IN METER
PANEL FOR CABLE ACCESS

	0	APPROVED FOR INSTALLATION	R.W.	4.9.09	N.C.	DES N.COAD	FIG.22C POLYPHASE WHOLE CURRENT METER DRILLING DETAILS FOR CABLE ACCESS SHEET 3
	A	ISSUED FOR COMMENT	R.W.	4.9.09	N.C.	DRN R.WILLIAMS	
						CKD N.COAD	
						APPD B.KISON	
	NO	DESCRIPTION	DRN	DATE	APPD	SCALE 1:5	A4 DRAWING NUMBER S11-2-7-23
						ISSUED 4.9.09	
AMENDMENTS						ALL DIM. IN mm	AMDT
						DRAFTING STANDARD TO A.S.1100	
						CAD PRODUCT — DO NOT AMEND MANUALLY	