



LV-LINE, 5 WIRE

MATERIAL: 150x75x5 DURAGAL CC
 STRENGTH: 7.2kN
 STOCK CODE: 406613

LV - TRANSFORMER AND CABLE TERMINATION 5 WIRE

MATERIAL: 150 x 75 x 5 DURAGAL PFC
 STRENGTH: 4.4kN
 STOCK CODE: 406610

NOTE: ALL HOLES ARE TO BE ON BOTH SIDES OF THE DURAGAL CC

NO	DESCRIPTION	DRN	DATE	CKD	APPD
2	NOTE ADDED, CENTER LINES EXTENDED	A.T.	DEC'11	B.C.	S.C.
1	TRANSFORMER CROSSARM AMENDED	A.S.	APR'07	R.S.	S.C.
0	ISSUED FOR CONSTRUCTION	K.I.	SEP'05	C.C.	C.C.
AMENDMENTS					



DES	C.T.F.	POWER STANDARD DRAWING		
DRN	K.I.	CROSSARMS LV 5 WIRE BOLTED CONNECTIONS FOR UNIVERSAL POLE CONSTRUCTION		
CKD	C.C.			
APPD	C.C.			
SCALE	1:20			
ISSUED	AUG '05	A3	DRAWING NUMBER	S01-1-2-20
ALL DIM. IN mm				
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT