



COLD APPLIED INSULATING BOOT

STOCK CODE:406928

MAX BUSHING DIAMETER: 70mm
 MAX CABLE CROSS SECTION: 400mm²
 MAX SYSTEM VOLTAGE: 17.5kV

NO	DESCRIPTION	DRN	DATE	CKD	APPD
3	SUPERSEDED	A.T.	DEC'12	B.C.	B.C.
2	DWG NUMBER CHANGED	J.C.	2.12.08	B.C.	S.C.
1	STOCK CODE ADDED. DRAWING No. CHANGED	A.S.	4.04.07	R.S.	S.C.
0	ISSUED FOR COMMENTS	K.I.	16.01.07		
AMENDMENTS					



DES	R.S.	POWER STANDARD DRAWING		
DRN	K. IBBOTT	INSULATING BOOT		
CKD	PWC			
APPD			
SCALE	N.T.S.			
ISSUED	JAN 07	A3	DRAWING NUMBER	S02-1-2-19
ALL DIM.	IN mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		 AMDT