

Connection Code Bulletin 2006 – 8

Issue/s: SN8 and SN10 PVC Sewer Pipe
Audience: Proponents, Project Managers, Designers, Construction Supervisors and Contractors
Date: 21 September 2006

Introduction

The use of SN4 or SN6 PVC sewer pipe for new Power and Water infrastructure is no longer permitted.

This change aligns with the practice of most interstate utilities.

When will this change be implemented?

All recent sewer reticulation approvals from Power and Water have been based on the use of SN8 and SN10 pipe.

How Can I Get More Information?

The Land Development section of Power and Water administers the Connection Code and associated activities including the asset creation process for Power and Water's water supply and sewerage infrastructure. Contacts are:

Northern Region

Land Development North
Water Operations Building
Ben Hammond Complex
Iliffe Street, Stuart Park
Telephone: (08) 8924 5282
Facsimile: (08) 8924 5287
LandDevelopmentNorth@powerwater.com.au

Southern Region

Land Development South
Sadadeen Valley
Berger Court, Alice Springs
Telephone: (08) 8951 7312
Facsimile: (08) 8951 7347
LandDevelopmentSouth@powerwater.com.au