

DN150 / DN225 IN-LINE GAS TRAP

DN225 GAS TRAP ACCESS CHAMBER

FABRICATED DN225 PVC DISCONNECTOR TRAP AS SHOWN



TYPICAL VIEW OF BENCHING TO GAS TRAP ACCESS CHAMBER



DN150 GAS TRAP ACCESS CHAMBER

FABRICATED DN150 PVC DISCONNECTOR TRAP AS SHOWN

NOTES:

1. REFER TO STANDARD DRAWINGS W2-2-01A, W2-2-1D, W2-2-02 AND W2-2-04 FOR GENERAL DETAILS OF ACCESS CHAMBER CONSTRUCTION. INCLUDING LENGTHS 'L1' AND 'L2'.
2. ALL PVC PIPES AND FITTINGS FOR GAS TRAPS ARE TO BE SN8 AND SHALL BEAR THE STANDARDS MARK FOR PRODUCT COMPLIANCE WITH AS 1260.
3. GAS TRAP ACCESS CHAMBER IS TO BE LOCATED WITHIN 3m. OF TRUNK SEWER ACCESS CHAMBER (WALL TO WALL). INTERMEDIATE INSPECTION OPENING OR ACCESS CHAMBER, AS APPLICABLE, ON IN-LINE GAS TRAP TO BE LOCATED AS CLOSE AS PRACTICABLE TO TRUNK SEWER.
4. AN IN-LINE GAS TRAP OR GAS TRAP ACCESS CHAMBER IS TO BE PROVIDED BETWEEN UPSTREAM RETICULATION SEWERS (DN150 AND DN225) AND DOWNSTREAM TRUNK SEWER (DN300 OR LARGER, OR OTHERWISE DIRECTED BY PWC.

NO	DESCRIPTION	DRN	DATE	CKD	APPD
3	GENERAL AMENDMENTS 2018.	P.W.	SEPT' 18	I.L.	D.C.
2	ACCESS CHAMBER WIDTH AND NOTES AMENDED.	RGI	JUN' 07	R.J.	J.P.
1	POSITION OF WATER SEAL SHIFTED.	RGI	MAR' 97	CSP	NWM

AMENDMENTS

PowerWater
NORTHERN TERRITORY

DES	C.PASCOE
DRN	R.INNES
CHK	C.PASCOE
APPD	H.YAU
SCALE	N.T.S.
ISSUED	30/10/96
ALL DIM. IN mm	
DRAFTING STANDARD TO A.S.1100	

SEWERAGE STANDARD DRAWING
SEWER MAINS - ACCESS CHAMBERS
IN-LINE GAS TRAP AND
GAS TRAP ACCESS CHAMBER

A3 | DRAWING NUMBER W2-2-06 | 3 AMDT

CAD PRODUCT - DO NOT AMEND MANUALLY