


ELEVATION
MARKER POST
(NOT FOR ABORIGINAL COMMUNITIES)

NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS NOTED OTHERWISE.
2. ENGRAVE OR SCORE MARKING TO SURFACE OF CONCRETE MARKER TO INDICATE DIRECTION AND NOMINAL DIAMETER OF SEWER RISING MAIN. DIRECTIONAL MARKING TO BE 100 MIN HIGH x 80 MIN WIDE x 5 MIN STROKE WIDTH x 5 MIN DEEP.
3. USE CONCRETE OF GRADE N25 MIN (25 MPa. 20 MAX SIZE AGGREGATE COMPLYING WITH AS1379).
4. USE ONLY THOSE MANUFACTURER'S PRODUCTS SHOWN APPROVED IN THE WATER AND SEWERAGE INFRASTRUCTURE PRODUCTS MANUAL.

2	GENERAL AMENDMENTS 2018. MARKER POST LETTERING CHANGED.	P.W.	SEPT' 18	I.L.	D.C.	 NORTHERN TERRITORY	DES	P.S. / L.W.	SEWERAGE STANDARD DRAWING		
1		RGI	AUG' 08	R.J.	J.P.		DRN	A.GRAY	MAINLAYING		
							CHK	I.WIGHT	SEWER RISING MAINS		
							APPD	N.McCARTHY	LOCATION MARKING		
							SCALE	N.T.S.			
							ISSUED	MAY' 01	A3	DRAWING NUMBER	W2-2-09
NO	DESCRIPTION	DRN	DATE	CKD	APPD						
AMENDMENTS											
DRAFTING STANDARD TO A.S.1100											
CAD PRODUCT - DO NOT AMEND MANUALLY											
AMD											