



NOTES:

1. UNIT 1 METER BOX TO BE SIMILAR TO NQDIN
2. UNIT 2 AND 3 METER BOX TO BE SIMILAR TO TB1614/U
3. MAIN SWITCHBOARD ARRANGEMENT (AS SHOWN IN UNIT 1) CAN BE EITHER UNIT 1,2 OR UNIT 3 DEPENDING ON THE MOST PRACTICAL POSITIONING OF THE POINT OF ATTACHMENT IN RELATION TO THE NETWORK.
4. METER BOX UNIT 2 AND 3, MAIN EARTH CONNECTION INTO METER BOX, SHALL BE EITHER CONTINUOUS EARTH THROUGH EARTH LINK OR A SWEATED JOINT.
5. ALL MAIN EARTHS BETWEEN THE MAIN EARTH LINK AND THE CONSUMERS SWITCHBOARDS SHALL BE A MINIMUM OF 6sqmm.
6. ALL CONSUMER MAINS AND CABLES, OTHER THAN NEUTRAL SCREEN CABLES, SHALL BE RUN IN CONDUIT.
7. ALL WIRING SHALL COMPLY WITH ALL RELEVANT AUSTRALIAN STANDARDS AND NORTHERN TERRITORY LEGISLATION.
8. CIRCUIT BREAKERS SHALL BE 63A, 10KA, C CURVE WITH INTEGRAL PADLOCKING ARRANGEMENT AND SEALABLE ENCLOSURE.
9. CIRCUIT BREAKERS SHALL BE 100A, 10KA, C CURVE WITH INTEGRAL PADLOCKING ARRANGEMENT AND SEALABLE ENCLOSURE.

NO	DESCRIPTION	DRN	DATE	CKD	APPD
4	NOTE 9 ADDED, AND CIRCUIT BREAKER LAYOUT AMENDED	K.T.	AUG '16	G.H.	G.H.
3	NOTE 8 ADDED, AND CIRCUIT BREAKER CHANGED	A.S.	APR '14	A.T.	G.H.
2	NOTES 5,6 & 7 ADDED. TRIPLEX PREPAYMENT METERING ARRANGEMENT ADDED AS PER PWC STANDARDS	A.C.S.	APR '13	A.T.	G.H.
1	ADAPTED FROM B10-14324		SEP 2010	A.T.	G.H.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES G Harbidge	REMOTE COMMUNITIES		
DRN H Gould	INDIGENOUS DUPLEX/TRIPLEX HOUSING		
CKD G Harbidge	REMOTE COMMUNITIES		
APPDT Greenwood	PREPAYMENT METERING ARRANGMENT		
SCALE			
ISSUED	A3	DRAWING NUMBER	S11-2-7-52
ALL DIM. IN mm			
DRAFTING STANDARD TO A.S.1100	CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT