



ITEM 1 SHOWN

CONDUIT PLUGS FOR SEALING CONDUITS AS WHERE THEY ENTER INDOOR SUBSTATIONS, SWITCHING STATIONS AND INTAKE STATIONS.  
 ALL PLUGS COME WITH SEGMENTED RINGS TO FIT SPECIFIC CABLE DIAMETER.  
 FOLLOW ALL INSTRUCTIONS INCLUDED IN THE PACKAGING.

ITEM	STOCK CODE	CONDUIT DIAMETER	CABLE DIAMETER RANGE	NUMBER OF CABLES	USEAGE	MATERIAL
1	503123	100mm	8-30mm	4	LV DISTRIBUTION	POLYMERIC
4	503121	150mm	25-54mm	3	HV CABLES EXCEPT 630sqmm	POLYMERIC
5	503122	150mm	12-75mm	1	400 AND 630sqmm HV CABLES	STAINLESS STEEL

						DES	A. TAYLOR	POWER STANDARD DRAWING			
						DRN	A. TAYLOR	CONDUIT ACCESSORIES, CONDUIT SEALING PLUGS			
						CKD	I. BASHIR				
						APPD	B. CHEUNG				
						SCALE	N. T. S.				
						ISSUED	FEB'15	A3	DRAWING NUMBER	S02-1-9-04	
						ALL DIM. IN	mm				
						DRAFTING STANDARD TO A.S.1100			CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT
0	ISSUED FOR CONSTRUCTION					A. T.	MAR'15	I. B.	B. C.		
NO	DESCRIPTION					DRN	DATE	CKD	APPD		
AMENDMENTS											
 <b>NORTHERN TERRITORY</b>											