



NOTES:

1. EASEMENT GROUND SHALL BE LEVEL REGARDLESS OF EXISTING GROUND PROFILE, REFER DETAIL A.
2. WHERE REQUIRED, A RETAINING WALL SHALL BE BUILT ALONG THE OUTER EDGE OF THE EASEMENT WITH THE ABILITY TO DIVERT FLOWING WATER AROUND THE EASEMENT.
3. ALL RETAINING WALLS SHALL BE CERTIFIED BY A CIVIL ENGINEER.
4. OPTIONAL 50mm WIDE CONCRETE STRIP FOOTING CAN BE BUILT ALONG THE EASEMENT EDGE.
5. THIS DRAWING SHALL BE APPLICABLE TO ALL GROUND MOUNTED INSTALLATIONS E.G. SUBSTATIONS, RMUS, ETC.
6. FOUNDATION AND APRON SHALL BE FINISHED TO PREVENT WATER POOLING. ADDITIONAL GUTTERING OR DRAINAGE MAY BE REQUIRED IN PROBLEM AREAS.

NO	DESCRIPTION	DRN	DATE	CKD	APPD
3	CONCRETE APRON DIMENSION CHANGES	P.H.	DEC'17	B.C.	B.V.
2	ADJUSTED FOUNDATION	CWM	AUG'17	B.V.	B.C.
1	CONCRETE APRON RAISED	A.T.	MAR'15	I.B.	B.C.
0	ISSUED FOR CONSTRUCTION	A.T.	JUL'13	B.C.	B.C.
AMENDMENTS					



DES	A.T.	POWER STANDARD DRAWING		
DRN	A.T.	GROUND LEVEL DETAILS PACKAGE SUBSTATIONS AND RING MAIN UNITS		
CKD	B.C.			
APPD	B.C.			
SCALE	N.T.S.			
ISSUED	MAY'13	A3	DRAWING NUMBER	S02-2-6-33
ALL DIM.	IN mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT