



CONDUIT ENTRY DETAILS

SCALE 1:25

NOTES:-
 CONDUIT ENTRY DETAILS TO BE USED WHEN INSTALLING MK2 SUBSTATION CONCRETE SLAB
 REF: S02-2-6-31_2

DOCUMENT No.	DOCUMENT TITLE
S02-1-7-18	SUBSTATION MK3 PACKAGE SUBSTATION GENERAL ARRANGEMENT
S02-2-5-10	EARTHING - PACKAGE SUBSTATION MK2 - CONSTRUCTION DETAILS
S02-2-6-23	GROUND LEVEL DETAILS - PACKAGE SUBSTATION AND MAIN UNITS
S02-2-6-38	MARK 3 SUBSTATION CONDUIT LOCATION STANDARD JIG
S02-2-6-41	CIVIL FOUNDATION SLAB MK3 PACKAGE SUBSTATION PRE-CAST SLAB
S02-2-6-37_2	CIVIL MK3 PACKAGE SUBSTATION CABLE ENTRY AND FOUNDATION DETAILS SETOUT DRAWING - SHEET 2 OF 4

NO	DESCRIPTION	DRN	DATE	CKD	APPD
0	ISSUED FOR CONSTRUCTION	CWM	Aug 17	I.B.	I.B.
AMENDMENTS					



DES	B.VDS	POWER STANDARD DRAWING		
DRN	CWM	CIVIL, MK3 PACKAGE SUBSTATION CABLE ENTRY AND FOUNDATION DETAILS WITH MK 2 SLAB SETOUT DRAWING		
CKD	I.B.			
APPD	I.B.			
SCALE	AS SHOWN			
ISSUED	Sep 2017	A 3	DRAWING NUMBER	S02-2-6-42
ALL DIM. IN mm				
DRAFTING STANDARD TO A S 1100		CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT