



CABLE RANGE	RANGE	PWC ITEM NUMBER
ACSR BANANA	6mm - 11.3mm DIA AAC/AAAC/ACSR	504043
ACSR APPLE		
AAAC FLUORINE		
ACSR RAISIN	6mm - 11.3mm DIA AAC/AAAC/ACSR	504044
ACSR CHERRY	10mm - 14.3mm DIA AAC/AAAC/ACSR	504045
AAC MERCURY AAC MARS AAC PLUTO AAAC NEON AAAC HYDROGEN	11mm - 18.8mm DIA AAC/AAAC/ACSR	504046

### NOTES

1. FOLLOW MANUFACTURERS INSTALLATION INSTRUCTION INCLUDED WITH SPLICE
2. ENSURE BOLTS ARE TIGHTENED IN THE CORRECT SEQUENCE, ALWAYS START ON THE OUTSIDE BOLT
3. DO NOT SHEAR BOTH HEADS FROM A BOLT AT THE SAME TIME, CORRECT SEQUENCE NEEDS TO BE FOLLOWED
4. SPLICE SHALL MEET REQUIREMENTS AS PER AS1154.1 - 2009

DRG NO	DESCRIPTION	NO	DESCRIPTION	DRN	DATE	CKD	APPD
x	x	2	CONDUCTOR ADDED	C.C.	SEP'18	B.V.	B.V.
		1	UPDATED ITEM No 504045 & 504046 DETAILS	P.H.	APR '18	I.B.	B.C.
		0	ISSUED FOR USE	C.C.	AUG '17	I.B.	B.C.
ASSOCIATED DRAWINGS		AMENDMENTS					



DES	POWER STANDARD DRAWING		
B.CHEUNG			
DRN	C.COPPINS	LINE HARDWARE	
CKD	I.BASHIR	SINGLE SLEEVE MECHANICAL SPLICE	
APPD	B.CHEUNG	FULL TENSION	
SCALE	N.T.S.	A3	DRAWING NUMBER S01-1-4-55
ISSUED	AUGUST 2017		
ALL DIM. IN mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	



AMDT