



VIEW A
SCALE 1:10

NOTES

1. NEUTRAL TO BE BONDED ON EVERY POLE VIA M12 NUTS WELDED INTO THE POLE.
2. COPPER NEUTRAL BOND TO BE FITTED BELOW ALUMINIUM CONDUCTORS.
3. FOR CORRECT APPLICATION OF HOOK BOLTS REFER DRGS. S4-2-2-2 & S4-2-2-4 FOR FULL DETAILS.

TAG No	QTY	DESCRIPTION	STOCK CODE	DRG REF
8	1	BRACE	298687	S01-2-1-49
7	1	LV-SERVICE CROSSARM 100x50x4 DURAGAL CC	298554	S01-1-2-11
6	1	LUG COMPRESSION 35 sq.mm	156240	
5	-	CABLE Cu PVC 35 sq.mm BLACK	1586	-
4	1	CONNECTOR, PIERCING 95/35	197723	S04-1-2-15
3	-	CABLE LV ABC, 4 x 95 sq.mm	197665	S04-1-1-01
2b		CLAMP SUSPENSION COMBINATION 4 x 95 sq.mm	198408	S04-1-2-10
2a		CLAMP SUSPENSION 4 x 95 sq.mm	197681	S04-1-2-10
1	1	HOOK BOLT M16	-	S04-1-2-07

MATERIAL SCHEDULE

						DES M. BOCK		POWER STANDARD DRAWING		
						DRN A. SCHMID		ASSEMBLIES LV - ABC - BOLTED CONNECTIONS INTERMEDIATE SUSPENSION		
CKD M. BOCK										
APPD F. ROBSON										
SCALE AS SHOWN										
						ISSUED AUG'01		A3	DRAWING NUMBER	S04-2-1-20
						ALL DIM. IN mm				
						DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		

NO	DESCRIPTION	DRN	DATE	CKD	APPD
0	ISSUED FOR CONSTRUCTION	A.T.	JUL'11	B.N.	B.C.
AMENDMENTS					