



NOTES:

1. ALL BOLTED CONNECTIONS TO USE GALVANIZED MILD STEEL BOLTS, SPRING WASHERS, LARGE FLAT WASHERS AND GALVANIZED NUTS.
2. GREASE TO USED ON ALL BOLTED CONNECTIONS.
3. REFER TO S01-2-7-12 SHEET 2 FOR GENERAL ARRANGEMENT
4. REFER TO S01-4-4-01 PN PROCEDURE 'POLE INSTALLATION PROCEDURE (CIVIL WORKS)' FOR THE REQUIREMENTS & INSTALLATION OF THE POLE CONCRETE FOUNDATIONS.

5	4	ANGLE CROSSARM BRACE	400815	S01-1-4-38
4	2	NOJA RECLOSER/VT MOUNTING PLATE	406941	S01-1-9-05
3	1	HV SURGE DIVERTER/LINK CROSSARM ASSEMBLY	413506	S01-2-1-39
2	1	CROSSARM HV TERMINATION, FIBREGLASS	414398	S01-1-2-10
1	1	LINE POLE, UNIVERSAL POLE	-	-
ITEM	QTY	DESCRIPTION	STOCK CODE	DRG REF
MATERIAL SCHEDULE				

						DES A. TAYLOR		POWER STANDARD DRAWING	
						DRN A. TAYLOR		POLE STRUCTURES - BOLTED CONNECTIONS NOJA RECLOSER	
CKD B. CHEUNG		A3	DRAWING NUMBER	S01-2-5-37					
APPD B. CHEUNG					ISSUED OCT '12	DRAFTING STANDARD TO A.S.1100	CAD PRODUCT - DO NOT AMEND MANUALLY		
SCALE 1:40				AMDT					
ALL DIM. IN mm									
AMENDMENTS									
NO	DESCRIPTION	DRN	DATE	CKD	APPD				
1	POLE FOUNDATION AMENDED, NOTE 4 ADDED	K.T.	JUN'16	I.B.	B.C.				
0	ISSUED FOR CONSTRUCTION	A.T.	OCT'12	B.C.	B.C.				