

**EVENT 2: 10/08/2017 Planned Islanding Event (RFA 13480):**

- 09:34:13 Islanded DA and PK-KA
  - P1, P2 and K4 online.
- 12:23:15 K1 Started
  - P1, P2, K1 and K4 online.
- 12:37:22 Islanded DA and PK and KA
  - P1 and P2 online in PK region.
- 12:39:33 DA-KA and PK
  - P1 and P2 online in PK region.
- 12:44:47 System restored, no islanding.

It is the determination of System Control that Territory Generation was not providing all ancillary services and EDL were providing Frequency Control Ancillary Services to the Pine Creek – Katherine or Pine Creek Island for the duration of the event. It would be unreasonable for EDL to pay Territory Generation for Ancillary Services EDL provided, thus the ASPrice is adjusted interval by interval to accommodate ASPrice of \$0.00 for the specific durations tabled below.

**Table 1: Calculation for ASPrice change – 10/08/2017 Interval 09:30 to 10:00**

Start Time	End Time	EDL Energy (MW/15s)
09:30:00	09:59:45	1188.74
09:30:00	09:34:15	174.35
	Proportion:	0.146668
	Price (= Proportion*5.40):	0.79

**Table 2: Calculation for ASPrice change – 10/08/2017 Interval 12:30 to 13:00**

Start Time	End Time	EDL Energy (MW/15s)
12:30:00	12:59:45	1119.71
12:45:00	12:59:45	932.46
	Proportion:	0.832769
	Price (= Proportion*5.40):	4.50

**Table 3: Event 2: ASPrice changes**

Interval Start Time	Interval End Time	ASPrice (\$/MWhr)
10/08/2017 9:30	10/08/2017 10:00	0.79
10/08/2017 10:00	10/08/2017 10:30	0.00
10/08/2017 10:30	10/08/2017 11:00	0.00
10/08/2017 11:00	10/08/2017 11:30	0.00
10/08/2017 11:30	10/08/2017 12:00	0.00
10/08/2017 12:00	10/08/2017 12:30	0.00
10/08/2017 12:30	10/08/2017 13:00	4.50