



**NOTES :**

1. MULTIMETERING WIRING ARRANGEMENT SHOWN WITH EXAMPLE OF 9 SINGLE PHASE METERS
2. THE ACTIVE LINKS, METER NEUTRAL LINK AND MAIN SWITCH ARE TO BE SEALABLE.
3. THE SERVICE CIRCUIT BREAKERS ARE RATED 63A, 10kA, CLASS C CIRCUIT BREAKERS
4. THE MAIN SWITCH SHALL BE A CIRCUIT BREAKER.
5. METER NEUTRAL WIRING TO BE NOT LESS THAN 4mm<sup>2</sup>.

	DES	BN	<b>WIRING SCHEMATIC FOR MULTIMETERING PANELS-EXAMPLE WITH 9 SINGLE PHASE METERS</b>			
	DRN	CM				
	CKD	BN				
	APPD	BN				
	SCALE	NTS				
NO	DESCRIPTION	DRN	DATE	APPD	ALL DIM. IN mm	
1	CHANGED NEUTRAL LINK	CM	2.5.13		<b>A4</b>	
0	ISSUED FOR INSTALLATION	CM	16.11.12			
<b>AMENDMENTS</b>						<b>DRAWING NUMBER</b>
DRAFTING STANDARD TO A.S.1100						<b>S11-2-7-53</b>
CAD PRODUCT — DO NOT AMEND MANUALLY						