



- NOTES:
1. REFER TO S02-2-3-08 FOR PILLAR CONSTRUCTION DETAILS.
 2. ITEM 4 ONLY REQUIRED FOR PILLARS HOUSING DESIGNED SYSTEM OPEN POINT.
 3. ITEM 3 TO BE PLACED AT BOTH VERTICAL AND HORIZONTAL CENTERLINE OF THE PILLAR DOOR.

ITEM	QTY	DESCRIPTION	STOCK CODE	DWG No.
4	1	RED REFLECTIVE STICKER INDICATING OPEN POINT	29433	-
3	1	SIGN, DANGER TRIANGLE STICKER, 100MM HIGH	412498	S02-1-8-03
2	1	SIGN, PILLAR NUMBER	29433	-
1	1	5 SLOT STRIPLE FUSE PILLAR	292334	S02-2-3-08

MATERIAL SCHEDULE

NO	DESCRIPTION	DRN	DATE	CKD	APPD
0	ISSUED FOR CONSTRUCTION	A.T.	APR'15	B.C.	B.C.
AMENDMENTS					



DES	A.T.	POWER STANDARD DRAWING		
DRN	A.T.	SIGN, STRIPLE FUSE PILLARS		
CKD	B.C.			
APPD	B.C.			
SCALE	N.T.S.			
ISSUED	NOV'14	A3	DRAWING NUMBER	S02-1-8-34
ALL DIM. IN mm				
DRAFTING STANDARD TO A.S.1100			CAD PRODUCT - DO NOT AMEND MANUALLY	

