

**NOTES**


1. FOR SERVICE CONNECTION ARRANGEMENTS REFER TO S04-2-1-25 AND S04-2-1-26.
2. DRIP LOOPS SHALL BE FORMED AT EVERY INSULATION PIERCING CONNECTOR
3. ALL INSULATION PIERCING CONNECTORS SHALL BE INSTALLED BELOW THE BUNDLED CABLE.
4. EYE BOLT/NON-BREAKAWAY CONSTRUCTIONS SHALL BE USED IN THE FOLLOWING SITUATIONS:
  - WHERE THE LINE DEVIATION ANGLE BRINGS THE CABLE OVER ANY ROADWAY
  - WHERE THE CABLE CROSSES OVER ANY ROADWAY, RAILWAY OR NAVIGABLE WATERWAY.
5. NEUTRAL CORE SHALL BE BONDED TO THE POLE EARTH AT EVERY POLE.

11	1	M12 COMPRESSION LUG FOR 35SQMM COPPER CABLE	402689	S02-1-2-11
10	AR	35SQMM PVC INSULATED COPPER CABLE	1586	S02-1-1-23
9	1	INSULATION PIERCING CONNECTOR 150/35	415586	S04-1-2-15
8	1	SERVICE CROSSARM	298554	S01-1-2-11
7	1	EYE NUT	298711	S01-1-4-41
6	1	M24 X 50 BOLT	114629	S01-1-4-43
5	1	LV ABC STRAIN CLAMP TO SUIT 4 X 95 AND 4 X 150SQMM CABLE	415585	S04-1-2-11
4	4	INSULATION PIERCING CONNECTOR 185/150	415587	S04-1-2-15
3	1	M16 HOOK BOLT	197731	S04-1-2-07
2	1	SUSPENSION CLAMP TO SUIT ARIAL BUNDLE CABLE	-	S04-1-2-10
1	AR	4 X 95 OR 4 X 150SQMM LV ABC	-	S04-1-1-01
<b>ITEM</b>	<b>QTY</b>	<b>DESCRIPTION</b>	<b>STOCK CODE</b>	<b>DWG No.</b>

**MATERIAL SCHEDULE**

NO	DESCRIPTION	DRN	DATE	CKD	APPD
0	ISSUED FOR CONSTRUCTION	C.C.	APR'12	A.T.	B.C.
<b>AMENDMENTS</b>					



DES	A.TAYLOR	POWER STANDARD DRAWING		
DRN	C.COPPINS	<b>POLE TOP UNITS</b>		
CKD	L.NIELSEN	<b>LV ABC, BOLTED POLE CONSTRUCTION</b>		
APPD	A.TAYLOR	<b>SUSPENSION ANGLE TEE-OFF</b>		
SCALE	N.T.S.	<b>ROAD SIDE</b>		
ISSUED	APR'12	<b>A3</b>	<b>DRAWING NUMBER</b>	<b>S04-2-1-24</b>
ALL DIM. IN	mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		 <b>AMDT</b>