



ENCLOSURE WITH KKT RMU: S/C 502381
 ENCLOSURE WITH KTK RMU: S/C 502380
 ENCLOSURE WITH KKK RMU: S/C 502383
 ENCLOSURE WITH KKKK RMU: S/C 502382

NOTES:

1. REFER TO S02-1-4-22 FOR DRIESCHER MINEX-C DETAILS
2. REFER TO S02-2-6-34 FOR FOUNDATION AND CIVIL WORKS DETAILS.
3. BOLT ENCLOSURE TO THE RMU FOUNDATION.

5	1	DRIESCHER MINEX-C RING MAIN UNIT	-	S02-1-4-22
4	1	WINDOW FOR FAULT INDICATOR	-	-
3	1	DRIESCHER RMU ENCLOSURE, NO RMU FITTED	502384	-
2	1	SIGN, AUTHORISED PERSONS ONLY, COMES INSTALLED	-	S02-1-8-31
1	1	SIGN, DANGER HIGH VOLTAGE, COMES INSTALLED	406832	S02-1-8-02
ITEM	QTY	DESCRIPTION	STOCK CODE	DWG No.

MATERIAL SCHEDULE

0	ISSUED FOR CONSTRUCTION	C.M.	NOV'12	A.T.	B.C.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	B. CHEUNG	POWER STANDARD DRAWING		
DRN	C. McLAREN	SWITCHGEAR DRIESCHER MINEX-C RMU ENCLOSURE		
CKD	A. TAYLOR			
APPD	B. CHEUNG			
SCALE	N. T. S.			
ISSUED	NOV'12	A3	DRAWING NUMBER	S02-1-4-27
ALL DIM.	IN mm	CAD PRODUCT - DO NOT AMEND MANUALLY		
DRAFTING STANDARD TO A.S.1100				

