



**NOTES :**

1. CUT CABLES TAILS TO LENGTH TO MAINTAIN CLEARANCE FROM POLE FOR INSULATED COMPRESSION JOINTS.
2. REMOVE INSULATION ON ABC TO DIMENSIONS SHOWN ON LINK AND ENSURE THAT CABLE IS FULLY INSERTED BEFORE COMPRESSION JOINT.
3. DO NOT USE INDENT DIE TOOL. USE 21.5mm COMPRESSION DIE ACROSS FLAT
4. REFER SERVICE DRAWINGS FOR SERVICE ARRANGEMENTS.
5. FULL TENSION LINK TO BE USED FOR NON-TENSION JOINTS.
6. FOR DETAILS OF FULL TENSION MID-SPAN JOINT SEE DRG. S4-1-2-17.
7. REFER TO S04-2-1-25 AND S04-2-1-26 FOR SERVICE ARRANGMENTS.

TAG No	QTY	DESCRIPTION	STOCK CODE	DRG REF
8	1	CABLE TIE BLACK 8mm	-	-
7	4	FULL-TENSION LINK INSULATED	-	S04-1-2-17
6	1	LUG COMPRESSION 35sq.mm	156240	-
5	-	CABLE Cu PVC 35sq.mm BLACK	1586	-
4	1	CONNECTOR, PIERCING 150/35	415586	S04-1-2-15
3	-	CABLE LV ABC,	-	S04-1-1-01
2	2	CLAMP STRAIN	415585	S04-1-2-11
1	2	HOOK BOLT M16	197731	S04-1-2-07

**MATERIAL SCHEDULE**

0	RENUMBERED FROM S01-2-1-35, MATERIALS AND NOTES UPDATED	J.C.	AUG'12	A.T.	S.C.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	B.T.KENT	POWER STANDARD DRAWING		
DRN	A.DAVIS	<b>ASSEMBLIES LV - ABC BOLTED CONNECTIONS NON-TENSION JOINT</b>		
CKD	R.INNES			
APPD	F.ROBSON			
SCALE	N.T.S			
ISSUED	MAY98	<b>A3</b>	<b>DRAWING NUMBER</b>	<b>S04-2-1-28</b>
ALL DIM. IN	mm			
DRAFTING STANDARD TO A.S.1100			CAD PRODUCT - DO NOT AMEND MANUALLY	

