



NOTES:

1. DOOR TO BE SOLID CORE EXTERIOR, SET IN A STEEL FRAME.
2. DOORS TO BE PAINTED BY BUILDER, COLOUR TO SUIT BUILDING.
3. ALL SIGNS TO BE INSTALLED BY CONTRACTOR/DEVELOPER.
4. THE ESCAPE PASSAGE MAY BE DELETED UNDER CERTAIN CIRCUMSTANCES - POWER AND WATER REQUIREMENTS WILL BE DISCUSSED AT THE DESIGN STAGE.
5. OPENING IN BLOCK WORK TO SUIT STEEL FRAME DOOR.
6. PERSONAL DOOR LOCK ARRANGMENTS REFER DWG S02-02-07-00.
7. PERSONNEL ACCESS DOORS SHALL ACHIEVE A MINIMUM FRL OF 2 HOURS.
8. SHALL COMPLY WITH BCA FIRE RESISTANT CONSTRUCTION, FIRE SEGREGATION REQUIREMENTS AS WELL AS VERIFIED AND TAGGED BY A CERTIFIED AUDITOR.
9. ALL SIGNAGE SHALL BE INSTALLED ON BOTH DOORS EXCEPT FOR THE SUBSTATION NUMBER WHICH SHALL BE INSTALLED ON THE MOST VISIBLE DOOR.
10. A 75mm WEATHER SHIELD SHALL OVERHANG THE TOP OF ALL EXTERIOR DOORWAYS.

	10 TITLEBLOCK & DRAWING NUMBERS FORMATTED 9 NOTE 6 AMENDED 8 DOOR DIMENSIONS AMENDED, NOTES 7, 8, 9, 10 ADDED, NOTE 6 AMENDED 7 DANGER SIGNS STOCK CODE UPDATED, SIGNAGE ADDED TO OUTER DOOR, EXIT SIGN STOCK CODES UPDATED 6 DANGER SIGNS UPDATED TO NEW LOGO, EXIT SIGNS ADDED 5 NOTE 6 ADDED 4 TRENCH LAYOUT AMENDED 3 REDRAWN, TITLE & DRG NUMBER CHANGED. NOTES ALTERED DOOR MEASUREMENTS ADDED	K.T. K.T. A.T. A.T. K.I.	FEB'19 JUN'16 JUN'14 MAR'13 02/05 09/90 03/90 11/88	C.C. A.T. B.C. B.C. R.C.	C.C. B.C. B.C. B.C. C.C.	 NORTHERN TERRITORY	DES ... DRN R.L.F CKD ... APPD B.KENT SCALE N.T.S. ISSUED 28/11/88 ALL DIM. IN mm	POWER STANDARD DRAWING INDOOR SUBSTATION DOOR EMERGENCY EXIT	A3 DRAWING NUMBER S02-02-07-04	
AMENDMENTS							DRAFTING STANDARD TO A.S.1100	CAD PRODUCT - DO NOT AMEND MANUALLY		