

SINGLE PHASE & RTE PACKAGE SUBSTATION					
TRF. kVA	H.V. CURRENT LIMIT ELX FS		H.V. CURRENT LIMIT ELX FS		ITEM NUMBER H.V. FUSE
	11kV				
	1 $\phi$		3 $\phi$		
	H.V.	L.V. MAX	H.V.	L.V. MAX	
50	15*	100	--	--	500771
75	25	100	--	--	9845
300	--	--	25	400	11098
500	--	--	40	500	247650
NOTES: *15A BAYONET FUSE LINK ADOPTED AS STANDARD FOR BOTH G.E. & TYRE 1 $\phi$ TRANSFORMERS IN THE URD SYSTEM.					

						DES	A.GREENWOOD	POWER STANDARD DRAWING	
						DRN	A.SCHMID	DESIGN DATA	
						CKD	A.GREENWOOD	FUSE CHARTS - MAJOR CENTRES	
						APPD	B.T.KENT	11KV RMU/SINGLE PHASE &	
						SCALE	N.T.S.	RTE SUBSTATIONS	
						ISSUED	NOV'91	A3	DRAWING NUMBER
						ALL DIM. IN mm			
						DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	
								AMDT	

7	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	APR'19	C.C.	C.C.
6	REMOVED FUSE & MCCB TABLED	K.T.	MAY'16	B.C.	B.C.
5	MCCB TYPE CHANGED	A.T.	AUG'14	B.C.	B.C.
4	REDRAWN, DRIESCHER MINEX RMU ADDED	A.S	NOV'12	A.T.	S.C.
3	REDRAWN IN CAD, 75KVA 1 PHASE SUBSTATION, DRIESCHER SWITCHGEAR ADDED	J.C.	JUN'10	A.T.	S.C.
2	TABLES AMENDED	J.C.	MAR'06	A.T.	S.C.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					

