



STANDARDS BRANCH
-POWER DIVISION-

PAGE : 1 OF 1
DATE : 16/2/87
REVISION : 0
DISTRIBUTION : VOLUME 2 HOLDERS
PREPARED BY : G. SCHUBERT
AUTHORIZED BY : BRIAN KENT

STANDARDS BULLETIN No. : S2-001

SUBJECT : CONTROL CABLE MULTICORE 250 VOLT

The following changes have been made to the specification for control cables multicore as shown on the standard drawing S2-1-1-3 (amd't 8).

1. The brass tape wrapping has been replaced with nylon extruded anti-termite jacket (black).
2. The orange PVC oversheath is changed to black. This due to problems of deterioration of the orange PVC when exposed to ultra violet light.

New stocks of these cables will be supplied to the amended specification.

BRIAN KENT
STANDARDS MANAGER POWER