



EARTHING REQUIREMENT

- FOR SUBSTATION EARTH, WITH LINKS 1 AND 2 OPEN, THE RECORDED EARTH RESISTANCE VALUE SHOULD NOT BE GREATER THAN 30 OHMS.
- FOR CMEN EARTH, WITH LINKS 1 AND 2 CLOSED, THE RECORDED EARTH RESISTANCE VALUE SHOULD NOT BE GREATER THAN 1 OHM.
- IF ANY OF THE ABOVE VALUES CANNOT BE ACHIEVED, REFER TO THE PROJECT MANAGER.
- 1 SPARE 10mm THREAD BOLT AND NUT FOR OPERATOR EARTHS ON THE HV AND LV EARTH BARS.
- WHERE ACCESS IS LIMITED, EARTHING STAKES IN THE EASEMENT CAN BE RELECTED TO THE CABLE TRENCH TO ENSURE THE SUBSTATION EARTH RESISTANCE IS LESS THAN 30 OHMS.
- TWO INDEPENDENT EARTHING CONNECTORS MUST BE USED FOR ALL EARTHING INTERCONNECTIONS, ALTERNATIVELY CADWELD MAY BE USED. MEN TEE OFF SHALL BE CONNECTED VIA 2 x "C" COMPRESSION CONNECTOR 300mm APART OR CADWELD.

NOTES:

- EARTHING FOR A 7000 SERIES PACKAGE SUBSTATION CONSISTS OF FOUR EARTH ELECTRODES IN THE EASEMENT AND IF REQUIRED THREE EARTH ELECTRODES IN THE CABLE ENTRY TRENCH.
- IN THE EASEMENT: FOUR BORE HOLES TO BE DRILLED AT CORNERS WITH A DISTANCE OF 2.7m APART. FOR EACH HOLE:
 - AUGER DIAMETER TO BE USED SHOULD NOT BE GREATER THAN 150mm.
 - BORE DEPTH IS 3m.
 - EARTH ELECTRODE SHALL BE MADE FROM EITHER BARE 70 sq.mm COPPER CONDUCTOR OR 70sq.mm BARE COPPER CONDUCTOR WITH AN EARTH STAKE ATTACHED VIA TWO PROFILE "6" COMPRESSION CONNECTOR BEFORE LOWERING THE STAKE INTO THE BORE HOLE. ATTACH THE 70 sq.mm COPPER CONDUCTOR TO THE EARTH GRID AS SHOWN IN DETAIL 1.
 - BACKFILL BORE HOLE FIRST WITH WATERED SLURRY MIXTURE OF ONE BAG OF EARTHING COMPOUND AND SOIL AT 1:1 RATIO, THEN TOP UP WITH EXISTING SOIL.
- IF REQUIRED TO ACHIEVE EARTHING REQUIREMENT NOTE 1, THREE ADDITIONAL EARTH ELECTRODES ARE TO BE INSTALLED AT THE BOTTOM OF THE CABLE ENTRY TRENCH WITH A DISTANCE OF 6m BETWEEN ELECTRODES AND TO A DEPTH OF 3m. A HAMMER CAN BE USED TO DRIVE CONNECTED EARTH RODS INTO THE GROUND, OR ALTERNATIVELY THE EARTH ELECTRODES CAN BE AS PER NOTE 2. DO NOT LET ANY OTHER EARTHING SYSTEM MAKE CONTACT WITH THE SUBSTATION EARTH. SEPERATE THIS LOCAL EARTH NETWORK AS FAR AS POSSIBLE FROM THE M.E.N. EARTH NETWORK
- EQUIPOTENTIAL EARTH GRID OF 300mm WIDTH MINIMUM TO BE LAID ACROSS AND CONNECTED TO FOUR EARTH ELECTRODES IN THE EASEMENT AS SHOWN BEFORE FORMING THE CONCRETE APRON FROM THE EASEMENT BOUNDARY TO THE SUBSTATION PAD FOUNDATION.
- FOR SUBSTATION FOUNDATION DETAILS, REFER TO DRAWING NO S02-02-06-09 & S02-01-05-13.
- M.E.N. EARTH (FROM DISTRIBUTION SYSTEM) MUST NOT BE BROUGHT INTO ELECTRICAL CONTACT WITH FOUNDATION SO THAT TESTING CAN BE CARRIED OUT. M.E.N. SHALL BE IN CONDUIT WHERE PASSING THROUGH CONCRETE FOUNDATIONS.
- TRAFFIC BOLLARDS SHALL BE CONNECTED TO PERIMETER EARTHING CONDUCTOR BY 70sq.mm COPPER CONDUCTOR WHICH WILL BE SET INSIDE THE POST AND LUGGED OFF ONTO A BARRIER BOLT. BOLLARDS ONLY TO BE EARTHED IF LOCATED WITHIN EASEMENT.
- WHERE EXTRA ROOM IN FRONT OF THE SUBSTATION IS REQUIRED, THE REAR MOST EDGE OF THE SUBSTATION FOUNDATION CAN BE MOVED BACK AS FAR AS THE OUTER EDGE OF THE EQUIPOTENTIAL EARTH GRID. THE EXTRA AREA BETWEEN THE SUBSTATION DOOR AND THE EQUIPOTENTIAL EARTH RING SHALL BE FILLED WITH EQUIPOTENTIAL EARTH RING, SET IN CONCRETE AND BONDED TO THE SUBSTATION EARTH GRID.
- BOND THE SUBSTATION FOUNDATION TO THE SUBSTATION EARTH RING VIA 70 sq.mm BARE COPPER CABLE USING THE M12 FERRULES EMBEDDED IN THE FOUNDATION, REFER S02-01-04-13. STAINLESS STEEL FASTENERS TO BE USED.
- FOR ANY EARTH CONNECTIONS TO EXISTING COPPER FLAT BAR USE CADWELD PLUS CONNECTION. CADWELD IS ALSO PERMITTED AS AN ALTERNATIVE TO CRIMPING. REFER TO DRG S02-01-05-03 FOR DETAILS.
- APPLY GREEN & YELLOW HEATSHRINK TO LOCAL SUBSTATION EARTH TAIL CONNECTIONS FOR IDENTIFICATION PURPOSES, AS TO BE CONSISTANT WITH PREVIOUS INSTALLATIONS BEING INSULATED CABLE.

ITEM	QTY	DESCRIPTION	ITEM NUMBER	DRG REF
7	4	EQUIPOTENTIAL EARTHING MASONRY WIRE MESH, GALVANISED, 400MM X 7.2MM DIA	288415	-
6	4	EARTHING COMPOUND (BAG)	10876	-
5	AR	COMPRESSION CONNECTOR, "6" PROFILE, 70 sq.mm	257394	S01-01-05-08
4	AR	COMPRESSION CONNECTOR, "C" PROFILE, 70-70 sq.mm	255786	S01-01-05-08
3	AR	EARTH ROD, SS316, 14mm DIA	414060	S01-01-05-01
1	AR	70sq.mm BARE COPPER CONDUCTOR.	9803	S01-01-05-05

MATERIAL SCHEDULE

NO	DESCRIPTION	DRN	DATE	CKD	APPD
29	UPDATED NOTES. TWO CRIMPS REQUIRED PER CONNECTION OR CADWELD. UPDATE EARTHING DESIGN. REMOVE ITEM 2. ADD NOTES 5 & 6 EARTHING REQUIREMENTS	CWM	OCT'21	A.N.	B.V.
28	UPDATE EARTHING MESH DETAILS.	H.E.	SEP'20	B.C.	B.V.
27	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	FEB'19	C.C.	C.C.



DES	G.McSHANAG	POWER STANDARD DRAWING	
DRN	T.R.	EARTHING PACKAGE SUBSTATION 7000 SERIES CONSTRUCTION DETAILS	
CKD	S.S.		
APPD	R.REYNOLDS	A3	DRAWING NUMBER S02-02-05-01
SCALE	1:50		
ISSUED	APR'85	DRAFTING STANDARD TO A.S.1100	
ALL DIM. IN mm			
CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT	