



CUBICLE SHALL BE PROVIDED WITH :

1. C20/40 RAILS FOR MOUNTING OF C.T.'s AND ESCUTCHEON.
2. C.T. MOUNTING COMPLETE WITH REMOVABLE BUSBAR & BUSBAR MOUNTING BLOCKS. ESCUTCHEON SHALL BE SEALABLE.
3. METAL SHIELDING BETWEEN METER AND INCOMING CONDUCTORS.
4. HINGED METER PANEL MINIMUM SIZE 500 x 500mm.
5. HINGED ESCUTCHEON PANEL.
6. PLINTH.
7. CUBICLE TO BE SIMILAR TO B AND R TYPE SMBI/20.

						DES .		POWER STANDARD DRAWING		
						DRN A.SCHMID		STANDARD C.T. METERING CUBICLE HINGED		
						CKD .				
						APPD .		A3 DRAWING NUMBER S11-02-07-29		
						SCALE NTS				
						ISSUED .		DRAFTING STANDARD TO A.S.1100		
						ALL DIM. IN mm				
						CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT		
1	TITLE BLOCK AND DRAWING NUMBER FORMATTED					CWM	OCT'20	BV	LH	
NO	DESCRIPTION					DRN	DATE	CKD	APPD	
AMENDMENTS										

