


DETAIL OF SLEEVE
95sq.mm SLEEVE SHOWN.


NOTES:

- 1. CABLE INSULATION TO BE REMOVED TO DIMENSION SHOWN ON LINK AND FULLY INSERTED INTO LINK BEFORE COMPRESSION.
- 2. JOINTS TO BE MADE WITH INDIVIDUAL CORE JOINTS STAGGERED MIN 150mm.
- 4. LINK TO HAVE EMBOSSED ON THE INSULATION:
 - STRIPPING LENGTH,
 - COMPRESSION DIE SIZE A/F,
 - NUMBER, LOCATION AND SEQUENCE OF COMPRESSIONS.
- 5. TO COMPLY WITH PWC SPECIFICATION STSP 05-013.

TABLE 1: ITEM DETAILS

ITEM REF.	CONDUCTOR C.S.A (sq.mm)	RATED TENSION (kN)	HEX. DIE A/F (mm)	ITEM NUMBER
1	95	16.8	21.5	229039
2	95	7	17.3	206664
3	150	7	21.5	415590

	8	AMENDED ITEM 3. ADDED NOTE 5.	P.BH.	NOV'22	B.V.	B.C.	DES	A.B.	POWER STANDARD DRAWING				
	7	REFORMATTED TABLE & TEXT. CHANGED ITEM 2 A/F. REMOVED COLOURS & NOTE 3	A.N.	AUG'21	A.N.	B.V.	DRN	A.DAVIS	LV AERIAL BUNDLED CABLE LINK - COMPRESSION				
	6	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	DEC'19	C.C.	C.C.	CKD	R.INNES					
	5	150sqmm VERSION ADDED	K.T.	MAR'12	B.C.	S.C.	APPD	F.ROBSON					
	4	AMENDED NOTES	K.T.	FEB'08	B.C.	S.C.	SCALE	N.T.S.					
	3	TABLE AND NOTE 4. AMENDED	K.T.	NOV'99	G.H.	F.R.	ISSUED	MAY'98	A3	DRAWING NUMBER	S04-01-02-17		
	2	NOTE 5 ADDED, DIMENSIONS 'A' AND 'B' REMOVED.	K.T.	MAY'98	R.I.	F.R.	ALL DIM. IN mm						
	1	REDRAWN ON CAD AND REVISED	R.T.F	OCT'89	-	G.S.	DRAFTING STANDARD TO A.S.1100	CAD PRODUCT - DO NOT AMEND MANUALLY				AMD T	
	NO		DESCRIPTION		DRN	DATE	CKD	APPD					
	AMENDMENTS												



NORTHERN TERRITORY

