



DETAIL OF SLEEVE
95sq.mm SLEEVE SHOWN.

NOTES:

1. CABLE INSULATION TO BE REMOVED TO DIMENSION SHOWN ON LINK AND FULLY INSERTED INTO LINK BEFORE COMPRESSION.
2. JOINTS TO BE MADE WITH INDIVIDUAL CORE JOINTS STAGGERED MIN 150mm.
4. LINK TO HAVE EMBOSSED ON THE INSULATION:
 - STRIPPING LENGTH,
 - COMPRESSION DIE SIZE A/F,
 - NUMBER, LOCATION AND SEQUENCE OF COMPRESSIONS.

TABLE 1: ITEM DETAILS

ITEM REF.	CONDUCTOR C.S.A (sq.mm)	RATED TENSION (kN)	HEX. DIE A/F (mm)	ITEM NUMBER
1	95	16.8	215	229039
2	95	7	17.3	206664
3	450	7	215	415590

7	REFORMATTED TABLE & TEXT. CHANGED ITEM 2 A/F. REMOVED COLOURS & NOTE 3	A.N.	AUG'21	A.N.	B.V.
6	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	DEC'19	C.C.	C.C.
5	150sqmm VERSION ADDED	K.T.	MAR'12	B.C.	S.C.
4	AMENDED NOTES	K.T.	FEB'08	B.C.	S.C.
3	TABLE AND NOTE 4 AMENDED	K.T.	NOV'99	G.H.	F.R.
2	NOTE 5 ADDED, DIMENSIONS 'A' AND 'B' REMOVED.	K.T.	MAY'98	R.I.	F.R.
1	REDRAWN ON CAD AND REVISED	R.T.F.	OCT'89	-	G.S.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	A.B.	POWER STANDARD DRAWING			
DRN	A.DAVIS	LV AERIAL BUNDLED CABLE LINK - COMPRESSION			
CKD	R.INNES				
APPD	F.ROBSON				
SCALE	N.T.S.				
ISSUED	MAY'98	A3	DRAWING NUMBER	S04-01-02-17	
ALL DIM.	IN mm			CAD PRODUCT - DO NOT AMEND MANUALLY	
DRAFTING STANDARD TO A.S.1100					AMDT