



NOTES :

1. MULTIMETERING WIRING ARRANGEMENT SHOWN WITH EXAMPLE OF 9 SINGLE PHASE METERS.
2. THE ACTIVE LINKS, METER NEUTRAL LINK AND MAIN SWITCH ARE TO BE SEALABLE.
3. THE SERVICE CIRCUIT BREAKERS ARE RATED 63A, 10kA, CLASS C CIRCUIT BREAKERS.
4. THE MAIN SWITCH SHALL BE A CIRCUIT BREAKER.
5. METER NEUTRAL WIRING TO BE NOT LESS THAN 4mm².
6. ALL NEUTRAL CABLES ARE TO BE CLEARLY MARKED/IDENTIFIED ACCORDING TO METER NUMBER.

2	TITLE BLOCK AND DRAWING NUMBER FORMATTED	CWM	OCT'20	BV	LH
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	B.NARAYANA	POWER STANDARD DRAWING			
DRN	CWM	WIRING SCHEMATIC FOR MULTIMETERING PANELS			
CKD	B.NARAYANA	- EXAMPLE WITH 9 SINGLE PHASE METERS			
APPD	B.NARAYANA	A3	DRAWING NUMBER	S11-02-07-53	
SCALE	NTS				
ISSUED	16.11.12	DRAFTING STANDARD TO A.S.1100			
ALL DIM.	IN mm	CAD PRODUCT - DO NOT AMEND MANUALLY			