



CUBICLE SHALL BE PROVIDED WITH :

1. C20/40 RAILS FOR MOUNTING OF C.T.'s AND ESCUTCHEON.
2. C.T. MOUNTING COMPLETE WITH REMOVABLE BUSBAR & BUSBAR MOUNTING BLOCKS. ESCUTCHEON SHALL BE SEALABLE.
3. METAL SHIELDING BETWEEN METER AND INCOMING CONDUCTORS.
4. FIXED METER PANEL MINIMUM SIZE 500 x 500mm.
5. FIXED ESCUTCHEON PANEL.
6. PLINTH.
7. CUBICLE TO BE SIMILAR TO B AND R TYPE SMBI/1.

SUPERSEDED

REFER DRG No. S01-02-07-30

							DES - DRN A.SCHMID CKD - APPD - SCALE NTS ISSUED - ALL DIM. IN mm	POWER STANDARD DRAWING		<b>A3</b> <b>DRAWING NUMBER</b> <b>S11-02-07-30</b>	 <b>AMDT</b>
1	TITLE BLOCK AND DRAWING NUMBER FORMATTED	CWM	OCT'20	BV	LH		<b>DRAFTING STANDARD TO A.S.1100</b> <b>CAD PRODUCT - DO NOT AMEND MANUALLY</b>				
NO	DESCRIPTION	DRN	DATE	CKD	APPD						
AMENDMENTS											