



LOCKABLE ISOLATOR DETAIL
NOT TO SCALE

- PUMP CHAMBER CONSTRUCTION NOTES**
- 1 CONCRETE PRECAST PUMP CHAMBER SECTIONS ARE TO BE DN1200 DN1500 OR A PWC APPROVED ALTERNATIVE
 - 2 SEAL INTERNAL AND EXTERNAL JOINTS WITH AN APPROVED EPOXY MORTAR OR EPOXY COMPOUND. ENSURE INTERNAL FACE OF JOINT IS FINISHED FLUSH WITH PIPES
 - 3 CONCRETE PRECAST SECTIONS TO BE LINED WITH AN APPROVED POLYUREA LINING
 - 4 ALL PIPE ENTRIES (CABLE DUCTS, ETC.) ARE TO BE PRE-DRILLED OR CORE DRILLED INTO THE CONCRETE

A	ISSUED FOR INFORMATION	P. Y.	01/01/16	G. H.	PWC
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	G. HARBIDGE	REMOTE OPERATIONS STANDARD DRAWING	
DRN	P. YOUNG	REMOTE OPERATIONS SERVICES	
CKD	D. ANNESLEY	SEWER HYDRAULIC AND ELECTRICAL	
APPD	PWC	SEPTIC TANK WITH A PUMP CHAMBER	
SCALE	NTS	STEP SYSTEM (PREVIOUSLY W2-4-02)	
ISSUED	JAN'16	A3	DRAWING NUMBER ROW2-4-03
ALL DIM.	IN mm		
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	

