



BRAND
PRODUCTION NUMBER
ON TOP AND
PACK NUMBER
ON THE BOTTOM
THIS END ONLY



TOP VIEW

PROD No.
PACK No.

VIEW A
SCALE 1 : 5



FRONT VIEW

NOTES:

1. FIBREGLASS CROSSARMS ARE PROVIDED WITH UV PROTECTIVE LAYER, THESE SHOULD BE HANDLED WITH CARE TO AVOID SCRATCHING ON THE SURFACE.
2. ALL ENDS FOR FIBREGLASS CROSSARM ARE TO BE WATER SEALED.
3. ALL HOLES IN FIBREGLASS CROSSARM ARE TO BE PROVIDED WITH INSERTS.
4. WHEN REMOVING FIBREGLASS CROSSARMS FROM POLE, LEATHER GLOVES, DUST MASKS AND SAFETY GLASSES MUST BE WORN. CROSSARM MUST BE WRAPPED IN PLASTIC A.S.A.P.
5. ALL FIBREGLASS CROSSARMS SHALL BE LABELED WITH THE DATE OF MANUFACTURE AND CROSSARM TYPE.
6. FOR WELDED CONSTRUCTION TO BE USED WITH THE ITEM No. 9274 BRACKET. REFER TO STD DRG No. S01-01-04-06.

ITEM 1 REPLACES:

- TIMBER TERMINATION CROSSARM SHOWN ON STD DRG No. S01-01-02-04, ITEM 1
- TIMBER INTERMEDIATE & ANGLE SUSPENSION CROSSARM SHOWN ON STD DRG No. S01-01-02-04, ITEM 2
- 2 TIMBER HIGH IMPULSE CROSSARM SHOWN ON STD DRG No. S01-01-02-08, ITEM 1
- STEEL 100 x 100 x 6 SHS HIGH IMPULSE CROSSARM SHOWN ON STD DRG No. S01-01-02-09, ITEM 1
- CROSSARM - STEEL REPLACEMENT FOR "TYPE X" ON STD DRG No. S01-01-02-14.

3	4	PLASTIC INSERT ASSEMBLY	-
2	6	PLASTIC INSERT ASSEMBLY	-
1	1	UNIVERSAL FIBREGLASS REINFORCED POLYMER CROSSARM 100x100x5	406748
TAG No.	QTY.	DESCRIPTION	ITEM NUMBER

5	NOTE 6 ADDED	H.E.	APR'20	B.C.	H.E.
4	TITLEBLOCK & DRAWING NUMBERS FORMATTED, NOTES ADDED	K.T.	DEC'18	C.C.	C.C.
3	INCLUDED 3 "Y-RACK" HOLES	P.H.	APR'18	J.B.	B.V.
2	CROSSARM REPLACEMENT S01-01-02-14 ADDED	K.I.	SEP'06	R.S.	S.C.
1	DIMENSIONS AMENDED	RAJ	JUL'06	RAJ	S.C.
0	ISSUED FOR CONSTRUCTION	A.S.	5.3.06	C.C.	C.C.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	C. CAMILLERI	POWER STANDARD DRAWING		
DRN	A. SCHMID	CROSSARM HIGH VOLTAGE FIBREGLASS REINFORCED POLYMER		
CKD	-			
APPD	C. CAMILLERI	A3	DRAWING NUMBER	S01-01-02-21
SCALE	1:10			
ISSUED	APR'06	DRAFTING STANDARD TO A.S.1100		
ALL DIM.	IN mm			
CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT		