



NOTES:

1. ALL BOLTED CONNECTIONS TO USE GALVANIZED MILD STEEL BOLTS, SPRING WASHERS, LARGE FLAT WASHERS AND GALVANIZED NUTS.
2. GREASE TO USED ON ALL BOLTED CONNECTIONS.
3. REFER TO S01-02-07-12 SHEET 2 FOR GENERAL ARRANGEMENT
4. REFER TO S01-04-04-01 PN PROCEDURE 'POLE INSTALLATION PROCEDURE (CIVIL WORKS)' FOR THE REQUIREMENTS & INSTALLATION OF THE POLE CONCRETE FOUNDATIONS.

5	4	ANGLE CROSSARM BRACE	400815	S01-01-04-38
4	2	NOJA RECLOSER/VT MOUNTING PLATE	406941	S01-01-09-05
3	1	HV SURGE DIVERTER/LINK CROSSARM ASSEMBLY	413506	S01-02-01-39
2	1	CROSSARM HV TERMINATION, FIBREGLOSS	414398	S01-01-02-10
1	1	LINE POLE, UNIVERSAL POLE	-	-
ITEM	QTY	DESCRIPTION	ITEM NUMBER	DRG No.

MATERIAL SCHEDULE

2	TITLEBLOCK & DRAWING NUMBERS FORMATTED	K.T.	JAN'19	C.C.	C.C.
1	POLE FOUNDATION AMENDED, NOTE 4 ADDED	K.T.	JUN'16	I.B.	B.C.
0	ISSUED FOR CONSTRUCTION	A.T.	OCT'12	B.C.	B.C.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					

PowerWater

NORTHERN TERRITORY

DES	A. TAYLOR	POWER STANDARD DRAWING	
DRN	A. TAYLOR	POLE STRUCTURES - BOLTED CONNECTIONS NOJA RECLOSER	
CKD	B. CHEUNG		
APPD	B. CHEUNG		
SCALE	1:40		
ISSUED	OCT '12	A3	DRAWING NUMBER S01-02-05-37
ALL DIM.	IN mm		
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	

