



**ITEM 1 - BRACKET-DOUBLE CLAMP MOUNTING**  
(ITEM NUMBER 203653)





**ITEM 3 - BRACKET HOOK MOUNTING**  
(ITEM NUMBER 203679)



**ITEM 2 - BRACKET OUTREACH MOUNTING**  
(ITEM NUMBER 203661)

#### NOTES

1. ALL WORKMANSHIP AND MATERIALS TO BE IN ACCORDANCE WITH AS 3678 & 3679.
2. ALL WELDING AND WELD PREPARATION TO BE IN ACCORDANCE WITH AS 1554. UNLESS INDICATED OTHERWISE, FILLET WELDS TO BE 6 mm U.N.O.
3. ALL ROUGH OR BURRED EDGES ARE TO BE DRESSED CLEAN.
4. BOLTS TO BE ISO METRIC AND PROPERTY CLASS 4.6 IN ACCORDANCE WITH AS 1111).
5. NUTS AND WASHERS TO BE IN ACCORDANCE WITH AS 1112 & AS 1237 RESPECTIVELY.
6. AFTER COMPLETION OF WELDING, ALL ITEMS ARE TO BE HOT DIP GALVANISED TO AS 1650.

3 2 1	SUPERSEDED ITEMS 1 AND 2. ITEM 3 IS OBSOLETE. UPDATE TITLEBLOCK AND DRAWING NUMBERS ITEM 2 MODIFIED TO ALLOW ATTACHMENT OF FUSE ASSEMBLY, NOTES MODIFIED.					J.R. C.C.	JUN'25 AUG'19	B.B. M.S.	B.V. C.C.	<div> NORTHERN TERRITORY</div>	DES	O.S.	POWER STANDARD DRAWING		
	NO	DESCRIPTION	DRN	DATE	CKD	APPD	DRN	G.MCK	LINE HARDWARE LV - ABC BRACKET DOUBLE CLAMP OUTREACH & HOOK MOUNTING		A3	DRAWING NUMBER	S04-01-02-02	<div></div>	
							CKD	G.SCHUBERT							
							APPD	B.T.KENT							
SCALE	1:5	ISSUED	SEPT'89	ALL DIM. IN mm	DRAFTING STANDARD TO A.S.1100	CAD PRODUCT - DO NOT AMEND MANUALLY	AMDT								
AMENDMENTS															