


MATERIAL SCHEDULE				
TAG No	QTY.	DESCRIPTION	STOCK CODE	DRG REF
1		LINE POLE	-	S1-1-1-2
2		LV CROSSARM	-	S1-1-2-1
3		25 x 4 COPPER BUSBAR (M)	3301	S1-2-3-3
4		LV SURGE DIVERTER	10041	S1-1-4-20
5		LV SURGE DIVERTER BRACKET	214932	S1-1-4-27
6		BOLT 1/2" G. C/Washer, FL. & Nut	114017	-
7		LV SURGE DIVERTER TAIL TO ISOLATING SWITCH	2147	S1-1-4-17
8		LV SURGE DIVERTER TAIL TO ISOLATING SWITCH	-	S1-1-6-1
9		LV SURGE DIVERTER TAIL TO ISOLATING SWITCH	-	S1-2-1-3
10		LV SURGE DIVERTER TAIL TO ISOLATING SWITCH	-	S1-2-1-6

SUPERSEDED

NOTES

1. ALL BUSBAR CONNECTIONS TO BE TINNED.
2. THIS ARRANGEMENT IS APPLICABLE TO BOTH 4 WIRE AND 5 WIRE SITUATIONS.
3. TERMINATE SURGE DIVERTER TAILS INTO ISOLATING SWITCHES.

1	NEUTRAL BOND CONNECTION RELOCATED TO CROSSARM STUD.	gmck	FEB'92	N.S.		DES	N.S.	N.T. STANDARD - POWER	
	DRN					gmck	POLE TOP UNITS LV SURGE DIVERTER ARRANGEMENT OPEN POINTS		
No.	AMENDMENT	DRAWN	DATE	APPD	NORTHERN TERRITORY	CKD	N.Stubbs	A3	DRAWING NUMBER S1-2-2-17
						APPD	B.T.Kent		
						SCALE	1:15 & 1:5		
						ISSUED	MAY'91		
						ALL DIM. IN	mm		
						DRAFTING STANDARD TO AS	1100	AMDT	