


ITEM	QTY	DESCRIPTION	ITEM NUMBER	DWG No.
18	1	ROUND POLE, 457mm DIAMETER	-	-
17	1	GAIN BLOCK, 125MM	-	-
16	3	TONGUE HOOK	292680	S01-01-03-09
15	3	THIMBLE CLEVIS	6767	S01-01-04-03
14	1	M24 BOLT AND NUT 500mm LONG, GALVANIZED	-	S01-01-04-45
13	4	M16 SPRING WASHER	113985	S01-01-04-45
12	4	M24 SPRING WASHER	113993	S01-01-04-45
11	4	M16 FLAT WASHER	114348	S01-01-04-45
10	8	M24 FLAT WASHER	298826	S01-01-04-45
9	2	M24 BOLT AND NUT 150mm LONG, GALVANIZED	-	S01-01-04-45
8	2	CROSS ARM BRACE ANGLE	400815	S01-02-01-49
7	1	M16 BOLT AND NUT 160mm LONG, GALVANIZED	114553	S01-01-04-45
6	1	M24 BOLT AND NUT 650mm LONG, GALVANIZED	-	S01-01-04-45
5	1	EYE NUT M24 FOR TERMINATION	298711	S01-01-04-41
4	1	CROSSARM, HV TERMINATION 125X125	414398	S01-01-02-10 2
3	2	SHACKLE HV STRAP FOR 125X125 FIBERGLASS TERMINATION CROSSARM	406938	S01-01-04-37
2	3	PREFORMED DEADEND TO SUIT CONDUCTOR	-	S01-01-04-18
1	3	22kV POLYMER SUSPENSION INSULATOR	292656	S01-01-03-09

**MATERIAL SCHEDULE**

NO	DESCRIPTION	DRN	DATE	CKD	APPD
3	SUPERSEDED.	H.E.	OCT'20	H.E.	B.V.
2	TITLEBLOCK & DRAWING NUMBERS FORMATTED	K.T.	JAN'19	C.C.	C.C.
1	CHANGE TO ROUND POLE	C.C.	OCT'11	A.T.	S.C.
0	ISSUED FOR CONSTRUCTION	J.C.	JAN'11	A.T.	S.C.



NORTHERN TERRITORY

POWER STANDARD DRAWING

**ASSEMBLIES. INSULATORS ON HV 'D' TOP FOR ROUND POLE CONSTRUCTION**

ISSUED OCT'11

ALL DIM. IN mm

DRAFTING STANDARD TO A.S.1100

A3

DRAWING NUMBER **S01-02-01-65**

CAD PRODUCT - DO NOT AMEND MANUALLY

3

AMDT