



NOTES:

1. ALL BOLTED CONNECTIONS TO USE GALVANISED MILD STEEL BOLTS, SPRING WASHERS, LARGE FLAT WASHERS AND GALVANISED NUTS.
2. GREASE TO USED ON ALL BOLTED CONNECTIONS.
3. REFER TO S01-04-04-01 PN PROCEDURE 'POLE INSTALLATION PROCEDURE (CIVIL WORKS)' FOR THE REQUIREMENT & INSTALLATION OF POLE CONCRETE FOUNDATIONS.

7	3	FLAT CROSSARM BRACE 50x5 CF	298687	S01-02-01-49
6	4	ANGLE CROSSARM BRACE 75x75x5 CA	400815	S01-02-01-49
5	1	CROSSARM, TRANSF & CABLE TERM, & M24 BOLT 220 LONG	298604	S01-01-02-12
4	1	CROSSARM, TRANSFORMER MOUNTING, & M24 BOLT 400 LONG	298596	S01-01-02-12
3	1	CROSSARM, HV EDD MOUNTING, & M24 BOLT 180 LONG	298547	S01-01-02-10
2	1	CROSSARM HV, & M24 BOLT 210 LONG	—	S01-01-02-10
1	1	LINE POLE	—	—
ITEM	QTY	DESCRIPTION	ITEM NUMBER	DRG No.

7	TITLEBLOCK & DRAWING NUMBERS FORMATTED	K.T.	JAN'19	C.C.	C.C.
6	NOTE 3 ADDED	K.T.	JUN'16	I.B.	B.C.
5	TRANSFORMER AND LV CROSSARM LOWERED 600mm	C.C.	MAR'12	A.T.	S.C.
4	LABELS AMENDED	A.S.	JUNE'05	R.C.	C.C.
3	ITEM 3 EDD CROSSARM LOWERED 600mm. ITEM 7 & 8 ADDED.	A.S.	JUNE'05	R.C.	C.C.
2	NOTE 3 ADDED & EARTHING ARRANGEMENT CHANGED	A.S.	MAR'02	R.C.	M.B.
1	ANGLE CROSSARM BRACE ADDED.	A.S.	APR'01	M.B.	F.R.R.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	M. BOCK	POWER STANDARD DRAWING		
DRN	R. INNES	POLE STRUCTURES - BOLTED POLES		
CKD	M. BOCK	SUBSTATION		
APPD	F. ROBSON	SINGLE POLE		
SCALE	1:40	A3	DRAWING NUMBER	S01-02-05-24
ISSUED	JULY'00			
ALL DIM.	IN mm	DRAFTING STANDARD TO A.S.1100		
CAD PRODUCT - DO NOT AMEND MANUALLY				

