



NOTES:

1. REFER TO DRAWING S02-02-06-01 FOR ALL TRENCHING NOTES.
2. POLYMERIC CABLE COVERS REQUIRED IN ALL TRENCH SECTIONS OUTSIDE OF THE FOOTPATH ALLOCATION EXCEPT FOR STREETLIGHT AND SERVICE TRENCHES.
3. POLYMERIC CABLE COVERS TO BE INSTALLED OVER AND EXTENDED 2m EITHER SIDE OF CABLE JOINTS AND 2m IN FRONT OF TERMINATIONS (eg PACKAGE SUBSTATIONS AND RMUs)
4. ALL TRENCH MAX DEPTH AT 1200 UNLESS PRIOR APPROVAL

NO	DESCRIPTION	DRN	DATE	CKD	APPD
14	AMEND STREETLIGHT CONDUIT POSITION. UPDATE DIMENSIONS. ROAD CROSSING CROSS SECTION MADE OBSOLETE.	C.C.	NOV'21	B.V.	A.N.
13	MIN & MAX DEPTH ADDED & NOTE 4 ADDED.	C.C.	JUN'19	B.V.	B.C.
AMENDMENTS					



DES		POWER STANDARD DRAWING	
DRN	N.S.	CIVIL	
CKD	G.I.	TRENCH SECTIONS OUTSIDE OF PWC	
APPD	N.S.	ROAD RESERVE ALLOCATION	
SCALE	B.T.K.	ALL AREAS	
ISSUED	1:15	A3	DRAWING NUMBER S02-02-06-03
ALL DIM. IN mm	JUNE 1991		
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	

