



NOTES :

1. METER INSTALLED BY PWC.
2. POTENTIALS ORIGINATE ON LINE SIDE OF C.T.'s.
3. CONNECTIONS AS PER SECTION 7.4(f) or 7.7(d) OF METER MANUAL.
4. INSTALLATION AS PER METER MANUAL SECTION 7 : LV CT METERING.
5. THE MAIN SWITCH SHALL HAVE PROVISION FOR SEALING.
6. CT TEST LINK SHOULD BE KWHTB02 or EQUIVALENT WITH THE S2 BRIDGE INSTALLED.
7. WIRING BETWEEN THE CT CHAMBER AND METER PANEL MUST BE INSTALLED IN STEEL ENCLOSED CABLE WAY (eg. DUCT, CONDUIT OR ANACONDA)

5	ADD NOTE 6 & 7. REMOVE ELECTRONIC METER, SOLDERED CONNECTION AND METER BOX EARTH.	CWM	17.12.2020	BV	LH
4	ADDED MAIN SWITCH & NOTE 5	CWM	20.11.12	BN	
3	UPDATED NOTES	CWM	29.6.12	BN	
2	RELOCATED FUSES	CWM	6.6.12	BN	
A	ISSUED FOR COMMENT	A.S.	24.3.02		
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	x	POWER STANDARD DRAWING		
DRN	C McLAREN	LOW VOLTAGE		
CKD	x	METERING WIRING DIAGRAM		
APPD	x			
SCALE	NTS			
ISSUED	x	A3	DRAWING NUMBER	S11-02-07-42
ALL DIM. IN mm				
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		

