



- NOTES:**
- NOTE 1 AND 10 REFER TO STD DRG W2-2-02.
 - REPLACE ALL CLASS C COVERS WITH CLASS D COVERS.
 - BENCH DETAILS APPLY TO PRECAST AND CAST IN-SITU BASES.
 - FOR FURTHER CONSTRUCTION NOTES REFER TO STD DRG W2-2-01D.
 - CAST IN-SITU CONCRETE SURROUND - REFER STD DRG W2-2-02.
 - LONGER AXIS OF RECTANGULAR COVERS TO RUN PARALLEL TO MAIN SEWER.

CIRCULAR ACCESS CHAMBER WITH RECTANGULAR COVER

NO	DESCRIPTION	DRN	DATE	CKD	APPD
4	NOTE 2 CHANGED.	P.W.	FEB' 19	J.R.	D.C.
3	GENERAL AMENDMENTS 2018.	P.W.	SEPT' 18	I.L.	D.C.
2	NOTE ADDED.	AW	JUN' 11	R.J.	J.P.
1	CAST IN-SITU CHAMBERS REMOVED.	RGI	AUG' 08	R.J.	J.P.
AMENDMENTS					



DES	C.PASCOE	SEWERAGE STANDARD DRAWING
DRN	R.INNES	SEWER MAINS - ACCESS CHAMBERS
CHK	C.PASCOE	CIRCULAR ACCESS CHAMBERS
APPD	H.YAU	(UP TO 6.0m DEEP)
SCALE	N.T.S.	A3
ISSUED	25/10/96	DRAWING NUMBER
ALL DIM. IN mm		W2-2-01A
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY