


HEATSHRINK INSULATING BUSHING BOOT
(ITEMS 1, 2, 3, 4, 5)



ELASTOMERIC INSULATING BUSHING BOOT
(ITEM 6)

FOR ADDITIONAL DETAILS REFER TO PWC JOINTING AND TERMINATION SPECIFICATION STSP 05-012

ITEM	TYPE	CABLE CROSS SECTION (mm ²)	BUSHING DIMENSION (mm)	TERMINATION	MAX SYSTEM VOLTAGE(KV)	ITEM NUMBER
1	HEATSHRINK INSULATING BUSHING BOOT	10-35	LENGTH 90-130	RIGHT ANGLE	17.5	3756
2	HEATSHRINK INSULATING BUSHING BOOT	50-95	LENGTH 60-90	RIGHT ANGLE	17.5	292177
3	HEATSHRINK INSULATING BUSHING BOOT	50-95	LENGTH 90-130	RIGHT ANGLE	17.5	3772
4	HEATSHRINK INSULATING BUSHING BOOT	120-300	LENGTH 90-130	RIGHT ANGLE	17.5	3780
5	HEATSHRINK INSULATING BUSHING BOOT	120-300	LENGTH 60-90	RIGHT ANGLE	17.5	292185
6	ELASTOMERIC INSULATING BUSHING BOOT	35-400	DIAMETER 46-70	INLINE OR RIGHT ANGLE	17.5	406928

<p>5 UPDATED TITLE & ADDED SPECIFICATON REFERENCE 4 TITLEBLOCK & DRAWING NUMBER FORMATTED 3 INCLUDED HEATSHRINK INSULATED BUSHING BOOT 2 DWG NUMBER CHANGED 1 STOCK CODE ADDED. DRAWING No. CHANGED 0 ISSUED FOR CONSTRUCTION</p>						R.A.	AUG'21	C.C.C.	B.V.	 NORTHERN TERRITORY	DES	POWER STANDARD DRAWING			
						K.T.	JAN'19	C.C.	C.C.		DRN	R.S.	CABLE JOINTING AND TERMINATIONS INSULATING MATERIALS BUSHING BOOT		
						C.C.	DEC'18	B.V.	B.C.		CKD	K. IBBOTT			
						J.C.	DEC'08	B.C.	S.C.		APPD	PWC....			
						A.S.	APR'07	R.S.	S.C.		SCALE	N.T.S.	ISSUED	JAN 2007	A3
K.I.	JAN'07	-	-	ALL DIM. IN mm		DRAFTING STANDARD TO A.S.1100	CAD PRODUCT - DO NOT AMEND MANUALLY	AMDT							
<p>NO DESCRIPTION DRN DATE CKD APPD</p>						<p>AMENDMENTS</p>									