



NOTES:

1. CIRCULAR PIPE COMPONENTS ARE TO COMPLY WITH THE REQUIREMENTS OF AS 1163.
2. ALL WORKMANSHIP AND MATERIALS TO BE IN ACCORDANCE WITH AS 1204.
3. ALL WELDING AND WELD PREPARATION TO BE IN ACCORDANCE WITH AS 1554.
4. ALL ROUGH OR BURRED SURFACES ARE TO BE DRESSED CLEAN.
5. AFTER FABRICATION AND CLEANING UP, THE COMPLETED OUTREACH IS TO BE GALVANISED IN ACCORDANCE WITH PAWA STANDARD TECHNICAL SPECIFICATION NO STS 029.
6. THE COMPLETED OUTREACH IS TO CONFORM WITH THE REQUIREMENTS OF AS 4100 AND AS 1798.

						DES DRN R. INNES CKD M. BOCK APPD P. DEWAR SCALE 1:2.5 ISSUED 11/9/96 ALL DIM. IN mm DRAFTING STANDARD TO A.S.1100		POWER STANDARD DRAWING BRACKET LANTERN OUTREACH POST TOP COLUMN A3		DRAWING NUMBER S03-01-03-09		
1	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	FEB'19	C.C.	C.C.							
NO	DESCRIPTION	DRN	DATE	CKD	APPD							
AMENDMENTS												