



NOTES :

- 1. 1.5 m OUTREACH SHOWN
- 2. SELECT ITEM 5 BASED ON POLE WIDTH FOR POLES LESS THAN 200mm WIDE USE ITEM No 203611.

ITEM	QTY.	DESCRIPTION	ITEM No	DRG REF
10	A/R	BOX, POLE MOUNTED CIRCUIT BREAKER	206490	S04-01-03-03
9	3	PIN, LINE INSULATOR, HV	-	S01-01-04-01
8	A/R	HOOK STRAP, SERVICE	9324	S01-01-04-07
7	1	CROSSARM, SERVICE	9555	S01-01-02-01
6	1	LV ABC - INTERMEDIATE SUSPENSION	-	S04-02-01-05
5	1	BRACKET, OUTREACH MOUNTING, ABC	8664/20366	S03-01-03-017 S04-01-02-02
4	1	LANTERN	-	S03-01-04-01
3	1	S/L OUTREACH	-	S03-01-01-10
2	1	CROSSARM - STEEL	-	S01-01-02-02
1	1	POLE, LINE	-	S01-01-01-02
MATERIAL SCHEDULE				

<p>3 TITLEBLOCK & DRAWING NUMBER FORMATTED 2 NOTE 2 ADDED, ITEM 5 ALTERNATIVE ADDED 1 DIMENSION FOR PLACEMENT OF MOUNTING BRACKET AMENDED & MATERIALS LIST ADD</p>						<p>K.T. DEC'19 C.C. C.C. K.I. SEP '05 C.C. C.C. J.A.L. MAY'95 A.G.B. P.J.D.</p>		<p>NORTHERN TERRITORY</p>	
NO	DESCRIPTION	DRN	DATE	CKD	APPD				
AMENDMENTS									

DES	B.T.KENT	POWER STANDARD DRAWING				
DRN	g.mck	ASSEMBLIES				
CKD	G.Schuber	LV - ABC				
APPD	B.T.KENT	SERVICES & STREET LIGHT				
SCALE	1:10	GENERAL CONSTRUCTION				
ISSUED	SEPT'89	A3	DRAWING	NUMBER S04-02-01-18		
ALL DIM.	IN mm					
DRAFTING STANDARD TO A.S.1100			CAD PRODUCT - DO NOT AMEND MANUALLY			AMD T