



**NOTES:**

1. BOLTS, WASHERS AND NUTS TO BE STEEL GALVANISED TO AS 1650.
4. INSERT TO BE NEOPRENE.
5. EACH DOUBLE AGSU TO BE SUPPLIED WITH YOKE PLATE AND OTHER NECESSARY COMPONENTS INCLUDING CLEVIS, BOLTS AND PINS. YOKE PLATE TO BE STRUCTURAL STEEL GRADE 250 TO AS 1204
6. MIN. FAILING LOAD: 70kN

DOUBLE ARMOUR GRIP SUSPENSION UNIT						
ITEM REF.	ITEM NUMBER	CONDUCTOR DIAMETER	CONDUCTOR	STRAP MATERIAL	HOUSING MATERIAL	RODS
1	239798	14.3	CHERRY	AL. ALLOY	AL. ALLOY	AL. ALLOY
2	239806	7.5	RAISIN	GALV. STEEL	GALV. STEEL	AL. ALLOY
3	286617	9.0	LIBRA FLOURINE APPLE	GALV. STEEL	GALV. STEEL	AL. ALLOY

NO	DESCRIPTION	DRN	DATE	CKD	APPD
5	UPDATED NOTE 5 TO INCLUDE OTHER ASSEMBLY COMPONENTS, JOINED HELICAL STRANDS TO GO FULLY ALL THE WAY THROUGH BOTH SUPPORTS	R.A.	AUG'21	C.C.C.	A.N.
4	REMOVED NOTES 2 & 3, UPDATED NOTE 5, ADDED NOTE 6. REFORMATTED TABLE AND ADDED MATERIALS.	A.N.	JUL'21	C.C.C.	A.N.
3	TITLEBLOCK AND DRAWING NUMBER FORMATTED	K.T.	DEC'18	C.C.	C.C.
2	ADDED ITEM 3, REDRAWN ON CAD	R.G.I.	FEB'97	A.G.B	F.R.R.
1	DIMENSIONS ADDED TO VIEW 'A'	GMCK	FEB'92	-	N.S.
AMENDMENTS					



DES	-	POWER STANDARD DRAWING		
DRN	G.L.	LINE HARDWARE DOUBLE ARMOUR GRIP SUSPENSION UNIT COMPLETE WITH YOKE PLATE		
CKD	N.S.			
APPD	B.T.K.			
SCALE	1:5			
ISSUED	MAY'91	A3	DRAWING NUMBER	S01-01-04-26
ALL DIM.	IN mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		5 AMDT