


DESIGN TENSION 18% UTS
AT 15°C NO WIND



'BANANA'

**KATHERINE & CENTRAL
AREAS ONLY**

3	TITLEBLOCK & DRAWING NUMBER FORMATTED	K. T.	APR'19	C. C.	C. C.
2	REDRAWN ON CAD	AD	12/97	MB	
1	NUMBER CHANGED		8/87		
NO	DESCRIPTION	DRN	DATE	CKD	APPD
	AMENDMENTS				



DES	R. REYNOLDS
DRN	RPP MAY'85
CKD	
APPD	R. REYNOLDS
SCALE	NTS
ISSUED	MAY'85
ALL DIM.	IN mm
DRAFTING STANDARD TO A.S.1100	

POWER STANDARD DRAWING	
SAG TENSION CHART	
6/1/3.75 A.C.S.R.	
'BANANA' CONDUCTOR	
CENTRAL REGION	
A3	DRAWING NUMBER S01-03-01-10
CAD PRODUCT - DO NOT AMEND MANUALLY	

