



**NOTES:**

1. BUSHINGS TO BE USED BETWEEN BUSBARS & FRAMING.
2. ALL CABLES TO BE COLOUR CODED WITH HEAT SHRINK AT BOTH ENDS.
3. ALL CABLES ENTERING/LEAVING TO HAVE DESTINATION TAGS. AS PER DRAWING S02-01-08-25.
4. READ IN CONJUNCTION WITH S02-01-07-01, STS001.
5. "Z" COVER PLATES FITTED BOTH SIDE OF BUS BAR MOUNTS.

**FRONT VIEW**

**SIDE VIEW**

**LV DISTRIBUTION CUBICLE**

(NOT SHOWING STRIPLE FUSE UNITS FOR CLARITY SEE S02-01-07-01 FOR STRIPLE FUSES)

6	AS REQ	INSULATING BOBBINS	-	S02-01-07-09
5	1	REMOVABLE LINK OR 90Sqmm Cu LUGGED CABLE	-	S02-01-07-09
4	1	EARTH BUSBAR - 50x6.3 TINNED Cu	-	S02-01-07-09
3	1	NEUTRAL BUSBAR - 50x6.3 TINNED Cu	-	S02-01-07-09
1	3	PHASE BUSBARS	-	S02-01-07-09
ITEM	QTY	DESCRIPTION	ITEM NUMBER	DRAWING No

MATERIAL SCHEDULE

NO	DESCRIPTION	DRN	DATE	CKD	APPD
2	UPDATE SPECIFICATION NOTE 4 & VARIOUS SPELLING CORRECTIONS & OBSOLETE	C.C.	FEB'21	B.V.	B.C.
1	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	APR'19	C.C.	C.C.



DES	POWER STANDARD DRAWING		
DRN	B.C.	PACKAGE SUBSTATIONS 7000 SERIES	
CKD	K.I.	LOW VOLTAGE COMPARTMENT	
APPD	B.C.	GENERAL ARRANGEMENT	
SCALE	S.C.	A3	DRAWING NUMBER S02-02-08-01
ISSUED	N.T.S.	DRAWING NUMBER S02-02-08-01	
ALL DIM'S	As Shown	DRAWING NUMBER S02-02-08-01	
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	

