



**NOTES:**

1. ALL WELDS AND BLACK METAL SURFACES TO BE CLEANED AND COATED WITH COLD GALVANISING COMPOUND.
2. COLUMN TO BE LEFT GALVANISED ACCORDING TO AS 1650 - NO PAINTING REQUIRED.
3. ALL ROUGH OR BURRED EDGES ARE TO BE DRESSED CLEAN.
4. ALL WELDING AND WELD PREPARATION TO BE IN ACCORDANCE WITH AS 1554.
5. CIRCULAR HOLLOW SECTION TO BE TO AS 1163 GR 250.
6. APPLY TWO COLLARS MANUFACTURED FROM 6mm PLATE SPACED A MINIMUM OF 100mm APART, TO TAKE UP SPACE BETWEEN PIPES PRIOR TO FINAL WELD.
7. SEE DRAWING S03-01-01-03 FOR DETAILS ON ITEM 3.



**TABLE 1**

ITEM	STOCK CODE	LENGTH	DIA A	NOM DIA
1	9647	9100	1800	190
2	9654	7500	1800	100
3	8938	9100	1700	150



NO	DESCRIPTION	DRN	DATE	CKD	APPD
9	SUPERSEDED BY S01-01-01-39	A.S.	APR '06	C.C.	C.C.
8	ADD ITEM 3 & NOTE 7. CHANGE TOP FLAT PLATE. REPLACE EARTH STUDS WITH TAB	K.I.	SEP '05	C.C.	C.C.
7	NEW TELESCOPING CONNECTION IN PLACE OF BUTT WELD FOR 9.1m POLE AND BUTT WELD REMOVED FROM 7.6m POLE. ITEMS SHOWN SEPERATELY.	RGI	MAR '00	SCM	FRR
6	REDRAWN ON CAD AND M12 x 40 STUDS ADDED.	JAL	MAR '95	SCM	PJD



DES	J.H.	POWER STANDARD DRAWING	
DRN	R.HAIGH	POLES SERVICE	
CKD	E.HENDERSON	7.6m AND 9.1m	
APPD	F.EVA	A3	DRAWING NUMBER S01-01-01-04
SCALE	N.T.S.		
ISSUED	JUN '79	DRAWING NUMBER S01-01-01-04	
ALL DIM.	IN mm	DRAWING NUMBER S01-01-01-04	
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	

