



EARTH TEST LINK BOLTED TYPE
 SCALE 1:2.5
 MATERIAL: 150 x 80 x 6 PLATE
 GRADE 316 STAINLESS STEEL
 REMOVE ALL BURRS AND ROUGH EDGES
 STOCK CODE: 298752

NOTES:

1. LOCATE TEST LINK ON THE STRONG SIDE OF THE POLE IN LINE WITH CENTRE OF POLE BRACE.
2. DRILL 3 x 13 DIA HOLES IN POLE AS PER EARTH TEST LINK DIMENSIONS.
3. ALL ROUGH OR BURRED SURFACES ARE TO BE DRESSED CLEAN.
4. TEST LINK TO POLE CONNECTION, USE 3 x M12 STAINLESS STEEL BOLTS CW STAINLESS STEEL FLAT AND SPRING WASHERS AND STAINLESS STEEL NUTS.

NO	DESCRIPTION	DRN	DATE	CKD	APPD
1	MADE OBSOLETE	A.S.	MAY'04	R.C.	M.B.
0	ISSUED FOR CONSTRUCTION	A.S.	7.3.01	M.B.	F.R.R.
AMENDMENTS					

PowerWater
 NORTHERN TERRITORY

DES	M. BOCK
DRN	R. INNES
CKD	M. BOCK
APPD	F. ROBSON
SCALE	MAY'00
ISSUED	1:2.5, 1:25
ALL DIM.	IN mm
DRAFTING STANDARD TO A.S.1100	

POWER STANDARD DRAWING

**EARTHING
 EARTH TEST LINK
 FOR UNIVERSAL POLE CONSTRUCTION**

A3	DRAWING NUMBER	S01-01-05-09
CAD PRODUCT - DO NOT AMEND MANUALLY		

