



3RD ANGLE -DO NOT SCALE - REPORT ANY ERRORS, OMISSIONS TO DRAFTING OFFICE



ELEVATION



SIDE VIEW

ITEM 1 - YOKE
ITEM NUMBER 218222

NOTES:

1. ALL WORKMANSHIP AND MATERIALS SHALL BE IN ACCORDANCE WITH AS 3678.
2. ALL ROUGH OR BURRED EDGES ARE TO BE DRESSED CLEAN.
3. CORROSION PROTECTION TO BE HOT DIPPED GALVANIZING, WHEREBY COMPONENTS ARE TO BE EVEN AND FREE OF LUMPS AND BUILD-UP AND TRUE TO SHAPE AFTER GALVANIZING. COMPONENTS ARE TO BE TESTED IN ACCORDANCE WITH AS 1650.
4. YORK HOOKS ARE TO BE CONSTRUCTED SUCH THAT THE CLOSING PLATE (ITEM NUMBER 213876) ON DRG. No. S04-01-02-07 CAN BE FITTED FOR NON-BREAKAWAY USAGE.

3	CHANGED 'STOCK CODE' TO 'ITEM NUMBER'. REFORMATTED TEXT	A.N.	AUG'21	A.N.	B.V.
2	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	DEC'19	C.C.	C.C.
1	REDRAWN IN CAD	A.D.	MAY'98	R.I.	F.R.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	gmck	POWER STANDARD DRAWING			
DRN	A.DAVIS	LINE H-RDW-RE LV - -BC YOKE FOR -NGLES 26-50 DEGREES			
CKD	R.INNES				
APPD	F.ROBSON				
SCALE	1:2	A3	DRAWING NUMBER	S04-01-02-08	
ISSUED	MAY'98			AMDT	
ALL DIM.	IN mm	DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	