



**NOTES**

1. ALL CLAMPS & BOLTED EARTH CONNECTIONS ARE TO BE WIRE BRUSHED BEFORE ASSEMBLING.
2. 12m CLEARANCE IS REQUIRED BETWEEN EARTH CONDUCTOR & HV CONDUCTORS.
3. RESISTANCE TO EARTH NOT TO EXCEED 10 OHMS.
4. REFER TO STD.DWG.No.S01-01-04-17 ITEM 6 IF NEUTRAL BOND DOES NOT REACH EARTH STUD.

**NO ANGLE**  
SCALE 1:10

**DEVIATION**  
SCALE 1:10

**TERMINATION**  
SCALE 1:10

NO	DESCRIPTION	DRN	DATE	CKD	APPD
2	TITLEBLOCK & DRAWING NUMBERS FORMATTED	K.T.	JAN'19	C.C.	C.C.
1	NEUTRAL BOND CONNECTION ALTERED	A.S.	18.6.04	R.C.	M.B.
0	ISSUED FOR CONSTRUCTION	A.S.	7.3.01	M.B.	F.R.R.
AMENDMENTS					



DES	M. BOCK	POWER STANDARD DRAWING	
DRN	A. SCHMID	ASSEMBLIES EARTHING CMEN UNDERSLUNG EARTH FOR UNIVERSAL POLE CONSTRUCTION	
CKD	M. BOCK		
APPD	F. ROBSON	A3	DRAWING NUMBER S01-02-01-27
SCALE	1:10		
ISSUED	MARCH '01	DRAFTING STANDARD TO A.S.1100	
ALL DIM.	IN mm		

